

SSO Notification List												
July 2010												
Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	7/1/2010	914 Wilmington Ave	21223	Rags, Roots & Grease	Gwynns Falls	2:00	9:10 AM - 11:10 AM	Heavy Gray Water	1,200	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	110871
2	7/1/2010	2039 Hillenwood Road	21239	Rags & Roots	Herring Run	0:55	1:20 PM - 2:15 PM	Gray Colored Water	110	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	110881
3	7/2/2010	5101 Pennington Ave	21226	Rags & Broken Pipe	Patapsco	15:37	7/2/10 5:23 PM to 9:00 AM 7/3/10	Heavy Gray Water	2,811	By-pass pumping sewage to stop overflow immediately.	Repair broken pipe	110928
4	7/4/2010	3703 Belair Road	21213	Rags & Grease	Herring Run	3:45	8:55 AM - 12:40 PM	Heavy Gray Water	2,250	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	110961
5	7/7/2010	1040 Wedgewood Road	21229	Rags, Roots & Grease	Gwynns Falls	3:00	10:18 AM - 1:18 PM	Heavy Gray Water	360	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111039
6	7/13/2010	3300 Weedon Street	21226	Rags & Debris	Inner Harbor	0:40	7:50 Pm - 8:30 PM	Sewer Water	200	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111265
7	7/16/2009	3609 Greenspring	21211	Rags & Grease	Gwynns Falls	5:00	9:00 Am - 2:00 PM	Heavy Gray Water	3,000	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111336
8	7/16/2010	1926 McCulloh Street	21217	Rags & Grease	Jones Falls	1:00	9:00 Am - 10:00 AM	Gray Colored Water	60	Used Electric Cutting Machine to Relieve House Connection	Turned lined over to be CCTV'ed	111337
9	7/18/2010	308 Radnor Ave	21212	Rags & Grease	Herring Run	1:00	8:10 AM - 9:10 AM	Gray Waster	60	Used Electric Cutting Machine to Relieve House Connection	Informed resident to stop putting grease down drain.	111392
10	7/18/2010	4600 Frederick Ave	21229	Pipe Break & Roots	Gwynns Falls	1:40	9:50 AM - 11:30 AM	Heavy Gray Water	300	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111376
11	7/22/2010	607 S Caton Ave	21229	Rags, Sand, Rocks & Grease	Inner Harbor	0:49	8:09 PM - 8:58 PM	Sewer Water	343	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111575
12	7/24/2010	3517 Hayward Ave	21215	Roots	Jones Falls	3:23	4:37 PM - 8:00 PM	Heavy Gray Water	203	Relieved H/C Choke with Pressure Truck	Turned lined over to be CCTV'ed	111630
13	7/24/2010	2601 Edmondson Ave	21223	Rags & Grease	Gwynns Falls	4:00	4:00 PM - 8:00 PM	Heavy Gray Water	1,200	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111635
14	7/25/2010	853 W. University Parkway	21211	Rags & Roots	Jones Falls	2:34	2:46 PM - 5:20 PM	Heavy Gray Water	462	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111656
15	7/26/2010	1115 N Woodington Ave	21229	Rags	Gwynns Falls	1:00	2:00 PM - 3:00 PM	Gray Water	300	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111689
16	7/26/2010	1410 Anglesea Street	21224	Sand	Inner Harbor	0:35	2:55 PM - 3:30 PM	Gray Colored Water	105	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111690
17	7/27/2010	2300 W Northern Parkway	21215	Rags	Jones Falls	0:55	10:50 AM - 11:45 AM	Rags & Gray Water	1,375	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111710
18	7/27/2010	532 Random Road	21229	Rags	Gwynns Falls	Unknown	7:30 PM - Unknown	Sewer Water (Street damp)	Evidence of Overflow	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111740
19	7/30/2010	2600 E Strathmore Ave	21214	Rags, Grease & Debris	Herring Run	2:05	5:25 PM - 7:30 PM	Sewer Water	625	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111855
20	7/30/2010	1200 Webster Street	21230	Grease	Inner Harbor	1:20	8:40 PM - 10:20 PM	Sewer Water	Evidence of Overflow	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111859
21	7/31/2010	3001 Iona Terrace	21214	Rags, Trash & Grease	Herring Run	1:30	11:55 AM - 1:25 PM	Gray Colored Water	180	Relieved M/L Choke with Pressure Truck	Turned lined over to be CCTV'ed	111892
22	7/31/2010	4033 Greenmount Ave	21218	Pipe Break	Inner Harbor	94:45	12:30 PM 7-31-2010 through 11:15 AM 8-3-2010	Gray Colored Water	2,842.5	Jetted M/L with Vac	Line to be TV'ed ASAP	111873
								TOTAL	17,987			